

Issue date:	Place:	Page:	Ident.
19.11.2019	Akland, Norway	1 of 1	SI2019-05

This document applies to:		Internal use:	External use:	X
Applies to:		Bulletin subject:		
WTD	X	Change Number of Rectifiers and Battery Packs ELECTRIC / HYDRAULIC DOORS WITH UPS		
SAFETY WINDOWS				
AUTOMATION				
Created by:		VML		
Approved by:		SRO / KRM		

CHANGE NUMBER OF RECTIFIERS AND BATTERY PACKS ON UPS SMARTPACK S MODULE – Part number 10024185 (if necessary)

1. Press up then down to unlock the menu
2. Go to system config
3. Go to rectifiers
4. Go to "NoOfModule(s)" and press enter
5. Passcode is 0003, press and hold enter to confirm
6. Change "NoOfModule(s)" to the number of rectifiers that are installed in the UPS
7. Press and hold enter
8. Go to Battery
9. Go to Battery Config
10. Change "NoOfBattery Strings" to the number of battery packs in the cabinet.
11. Press enter to confirm and press X to go all the way back to the main screen.



For more info and additional questions, please contact us at: service@imstec.no